


SRI BAALAMURUGAN BOREWELLS

4, gangamma Compound, Opp. Canara Bank Bus Stop, Bellary Main Road, Helibal Bangalore - 24.
Mob : 9845020536, 9901920004

WORK REPORT

Venkateshwara Nagar Kallipalya.			No.	
			Date :	
S.No.	Particulars	Rft :	Water Yield	Remarks
1.	Size of The Borewell	165 mm dia		
2.	Total Deapth of The Borewell	980 feet		
3.	MS Casing Erected	137 feet		
4.	1st Water Source at the Deapth	305 feet		
5.	2nd Water Source at the Deapth	516 feet		
6.	3rd Water Source at the Deapth	712 feet		
7.	4th Water Source at the Deapth	970 feet		
8.	If any Silt, Boulders at the Deapth	-		
9.	Nature of Water	Sweet water		
10.	Moter Pump to be Used	15 HP 30 Stage		
11.	Any other Remarks	-		
12.	Total Yield of the Borewell	2.5"		

Thanking You


yours faithfully
For Sri Baalamurugan Borewells

Name of Work: Drilling of Borewell and Providing Pump and Motor at Venkateshpura and palanahalli in Ward No. 05 Byatarayanapura Sub Division.

Venkateshpura
Kali Pal



Aji
Assistant Engineer
Ward No. 05


Mohana
Assistant Executive Engineer
Byatarayanapura Sub Division
BBMP Bangalore-24
ಬಿಬಿಎಂಪಿ, ಬೆಂಗಳೂರು-24

②
Name of Work: Drilling of Borewell and Providing Pump and Motor at Venkateshpura and palanahalli in Ward No. 05 Byatarayanapura Sub Division.

Venkateshpura
Kali Paly




Assistant Engineer
Ward No. 05


Assistant Executive Engineer
Byatarayanapura Sub Division
BBMP Bangalore-24
ಬಿಬಿಎಂಪಿ, ಬೆಂಗಳೂರು-24

(2)

GROUND WATER SURVEY REPORT

OPEN WELL/ BOREWELL DATA OF SURVEY

- a) Name of the Party : A E B Katarayana
b) Location of the Site : Ward no. 5 BBMP
c) Area of the land : Venkatesh nagara
(Kallipalya)

INVESTIGATION REPORT

- 1) GEOLOGY OF THE AREA :
- 2) Recommended Site for drilling :
- 3) Total depth to be drilled : 800' - 1100'
- 4) Approx. casing pipe required : 95' - 100'
- 5) No. of water bearing Zones : - 3'' -
- 6) No. of favourable spots marked : - 02 -
- 7) Qty. of water expected : - 3'' -
- 8) Method of survey carried out : mag - menad.
- 9) Remarks : 6 1/2" dia smaller w.s

P.T.O. : Terms & Conditions

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

AEOS
my

BOREWELL SITE PLAN

